



Materials/Finishes:	Electro-Galvanized (310NFG)	Plastic Coated 1/2" - 8" (310NFPC)
Variants:	Electro-Galvanized, 3/16" Felt-lined: 1/2" - 8" (310NFLL)	
Service:	Designed for the suspension of non-insulated stationary pipe lines. Typically used as a pipe support for sprinkler piping. Hanger is manufactured to use minimum rod sizes permitted by NFPA.	
Approvals:	U.L. - U.L.C. listed and FM approved (3/4"-8"). Complies with Federal Specification WW-H-171-E (Type# 10), A-A-1192 A (Type# 10) and Manufacturers' Standardization Society MSS SP-58 and SP-69 (Type# 10).	
Ordering:	Specify figure number, finish and pipe size.	
Notes:	UL approved on sized 2-1/2" - 4"/ FM approved on sizes 2-1/2" - 4"	



PIPE SIZE	PIPE OD	MATERIAL SIZE	A	B	C	E	F	G	WGT EACH (lbs)	MAX REC LOAD (lbs)
1/2	0.840	18ga x 5/8	3/8	2-1/2	2-7/8	1-5/8	1-3/16	7/8	0.08	400
3/4	1.050	18ga x 5/8	3/8	2-7/16	2-15/16	1-9/16	1-1/16	7/8	0.08	400
1	1.315	18ga x 5/8	3/8	2-5/8	3-1/4	1-3/4	1-1/16	7/8	0.08	600
1-1/4	1.660	18ga x 5/8	3/8	2-9/16	3-3/8	1-11/16	7/8	7/8	0.10	600
1-1/2	1.900	18ga x 5/8	3/8	2-11/16	3-5/8	1-13/16	7/8	7/8	0.10	600
2	2.375	18ga x 5/8	3/8	3-3/8	4-1/2	2-1/2	1-5/16	7/8	0.12	600
2-1/2	2.875	14ga x 3/4	3/8	3-7/8	5-3/8	3-1/8	1-3/8	7/8	0.24	600
3	3.500	14ga x 3/4	3/8	4-1/2	6-1/4	3-5/8	1-5/8	7/8	0.28	600
3-1/2	4.000	14ga x 3/4	3/8	4-7/8	6-7/8	4	1-3/4	7/8	0.32	600
4	4.500	14ga x 3/4	3/8	5	7-1/4	4-1/8	1-5/8	7/8	0.32	1000
5	5.563	13ga x 3/4	1/2	5-3/4	8-1/2	4-1/4	1-7/8	1-1/16	0.62	1000
6	6.625	12ga x 3/4	1/2	6-3/4	10-1/8	5-1/8	2-1/8	1-1/16	0.65	1250
8	8.625	11ga x 1	1/2	7-7/8	12-1/4	7	2-3/8	1-1/16	1.00	1250
10	10.750	11ga x 1-1/4	1/2	9-11/16	15-1/16	8-5/8	3-1/4	1-1/16	1.675	1250

PROJECT INFORMATION	APPROVAL STAMP
Project:	Notes:
Address:	
Contractor:	
Engineer:	
Date:	
Approved      Approved as Noted      Not Approved	